

**Company Health & Safety
Standard Method Statements and Bibliography**

**XII
Electrical Installation**

Guidance Notes

- HSE Electrical switchgear and safety
- IEE wiring regulations 16th edition

Forms

Risk assessment record.

1. No part of an electrical installation will be connected to a mains supply during installation.
2. All electrical installation work will be inspected by qualified personnel holding IEE 16th edition.
 - a. In particular
 - i. Supply side switch gear will be inspected for suitability of purpose (condition and rating) prior to connection.
 - ii. Insulation integrity will be tested prior to connection to a mains supply.
 - iii. Earth system integrity will be tested prior to connection to a mains supply.