

**Company Health & Safety  
Standard Method Statements and Bibliography**

**XII  
Electrical Installation**

Guidance Notes

- HSE Electrical switchgear and safety
- IEE wiring regulations 16<sup>th</sup> edition

Forms

Risk assessment record.

1. No part of an electrical installation will be connected to a mains supply during installation.
2. All electrical installation work will be inspected by qualified personnel holding IEE 16<sup>th</sup> edition.
  - a. In particular
    - i. Supply side switch gear will be inspected for suitability of purpose (condition and rating) prior to connection.
    - ii. Insulation integrity will be tested prior to connection to a mains supply.
    - iii. Earth system integrity will be tested prior to connection to a mains supply.